

Tehnički list za artikl: MGC52008--

Strujni transformator 75/5A 21 mm diameter, klasa 1

Ulazna struja 75A, Teret Class 1 (1.5VA)




Tehnički podaci

IP stupanj zaštite	IP20
Teret	Class 1 (1.5VA)
Naputak	Due to dangerous overvoltage and overheating, the Current Transformer is not allowed to be operated with open secondary Side. (EN 60044-1 /A2) As soon as the Measurement Device, the Energy Counter or the Net Analyzer is disconnected, the secondary Side has to be shortcuted!
Namjena korištenja	for cables up to diameter 21 mm
Norma	EN 61869-2
Otvor (mm)	21
Zahtjevi za izolaciju	
Maks. radni napon Um	0.72kV r.m.s.
Ispitni napon izolacije	3 kV R.M.S. 50 Hz/ 1 min
Izolacija	Class B (EN/IEC 61869-1, 61869-2)
Specifikacije	
Nazivna struja primara Ipr (A)	75
Nazivna frekvencija (Hz)	50-60Hz

Tehnički podaci - nastavak

Kratkotrajna struja I_{th}	< 60I _{pr}
Thermal rated continuous current according to EN60044-1	
Nazivna dinamička struja I_{dyn}	2.5I _{th}
Nazivna struja sekundara I_{sr}	5A
MOment pritezanja (Nm)	2
Materijal kućišta	Polycarbonate, self-extinguishing
Klase točnosti	
Referentna temperatura (°C)	23°C ±1°C
Greška struje opterećenja	For class 1 and 20% I _n : ±1.5% For class 1 and 5% I _n : ±3%. For class 1 and 100% I _n : ±1%. For class 1 and 120% I _n : ±1%
Radni uvjeti	
Temperaturno područje - Transport/Skladištenje (°C)	-25 to +60
Temperaturno područje - Pogon (°C)	-5 to +40

Maßbild MGC52008--



OPIS

Strujni transformator 75/5A 21 mm diameter, klasa 1
Ulazna struja 75A, Teret Class 1 (1.5VA)

KAT. BROJ

MGC52008