

Tehnički list za artikl: MGC56120--

Strujni transformator 1200A/5A, 60 x 30mm, klasa 0.5

Ulazna struja 1200A, Teret Class 0.5 (10VA)




Tehnički podaci

IP stupanj zaštite	IP20
Teret	Class 0.5 (10VA)
Naputak	Due to dangerous overvoltage and overheating, the Current Transformer is not allowed to be operated with open secondary Side. (EN 60044-1 /A2) As soon as the Measurement Device, the Energy Counter or the Net Analyzer is disconnected, the secondary Side has to be shortcuted!
Namjena korištenja	for copper bars up to 50 x 30mm for copper bars up to 60 x 10mm
Norma	EN 61869-2
Otvor (mm)	50x30 / 60x10
Zahtjevi za izolaciju	
Maks. radni napon Um	0.72kV r.m.s.
Ispitni napon izolacije	3 kV R.M.S. 50 Hz/1 min
Izolacija	Class B (EN/IEC 61869-1, 61869-2)
Specifikacije	
Nazivna struja primara Ipr (A)	1200

Tehnički podaci - nastavak

Nazivna frekvencija (Hz)	50-60Hz
Kratkotrajna struja I _{th}	< 60I _{pr}
Thermal rated continuous current according to EN60044-1	
Nazivna dinamička struja I _{dyn}	2.5I _{th}
Nazivna struja sekundara I _{sr}	5A
MOment pritezanja (Nm)	2
Materijal kućišta	Polycarbonate, self-extinguishing
Klase tačnosti	
Referentna temperatura (°C)	23°C ±1°C
Greška struje opterećenja	For class 0.5 and 5% I _n : ±1.5% For class 0.5 and 120% I _n : ±0.5% For class 0.5 and 100% I _n : ±0.5% For class 0.5 and 20% I _n : ±0.75%
Radni uvjeti	
Temperaturno područje - Transport/Skladištenje (°C)	-25 to +60
Temperaturno područje - Pogon (°C)	-5 to +40

Maßbild MGC56120--



OPIS

Strujni transformator 1200A/5A, 60 x 30mm, klasa 0.5

Ulazna struja 1200A, Teret Class 0.5 (10VA)

KAT. BROJ

MGC56120